Cross Shannon 400 kV Cable Project Capital Project 0970

Schedule 3 - Newspaper Notice Text

Newspaper	Date of Edition
Irish Independent	23 rd July 2020
Kerry's Eye	23 rd July 2020
Clare Champion	24th July 2020

PLANNING AND DEVELOPMENT ACT 2000 (AS AMENDED)

NOTICE OF DIRECT PLANNING APPLICATION TO AN BORD PLANÁLA FOR APPROVAL IN RESPECT OF A STRATEGIC INFRASTRUCTURE DEVELOPMENT (A PROPOSED ELECTRICITY TRANSMISSION DEVELOPMENT) CLARE COUNTY COUNCIL AND KERRY COUNTY COUNCIL

In accordance with Section 182A of the Planning and Development Act, 2000 (as amended), EirGrid Pk, with the consent and approval of the Electricity Supply Board (ESB), gives notice of its intention to seek the Approval of An Bord Pleandia in relation to a proposed electricity transmission infrastructure development and associated works (known as the 'Cross Shannon 400 kV Cable Project') generally comprising the laying of 400 kV underground cables (UGC) across the Lower Shannon Estuary, between the existing Moneypoint 400 kV Electricity Substation in the townland of Carrowdotta South Co. (Ure and the existing Kilpaddoge 220/110 kV Electricity Substation in the townland of Kilpaddoge, Co. Kerry: The proposed development comprises

in elements:

(Connection of a 400 kV UGC Installation at the Moneypoint 400 kV Electricity Substation (Connection of a 400 kV UGC Installation at the Moneypoint 400 kV Electricity Substation and 3

• the laying of 3 no. 400 kV UGC (approx. 1.8 kilometres (km) each) between the existing Moneypoint 400 kV Electricity Substation and 3

• the laying of 3 no. 400 kV UGC (approx. 1.8 kilometres (km) each) between the existing Moneypoint 400 kV Electricity Substation and 3

• the provision of 4 no. 1014-submarine transition foint bays along their length and the associated provision, upgrading and/or extension of existing internal access tracks to provide operational vehicular access.

• the provision of 4 no. Ind-submarine cables (this arrangement also includes a land-submarine transition for the spure submarine cable). It is a submarine cables (this arrangement also includes a land-submarine transition bays for the spure submarine cable).

Laying of 400 kV Submarine cables (approx. 2.8 km each) from the proposed land-submarine transition bays located east of the existing Moneypoint Generation Station in Co. Clare across the Lower Shannon Estuary to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Klipaddage 220/110 kV Electricity Substation in Co. Kerry. The submarine cables will be installed by standard submarine insulation techniques, which primarily involves them being buried in the seabed.

• the installation of communication links between both substations, this will take the form of a fibre optic cable that will be integrated into each of the proposed 400 kV and each of the cables.

• the installation of communication links between both substations; this will take the form of a fibre optic cable that will be integrated into each of the proposed 400 kV cables.

• The installation of fibre optic cables for maintenance and cable monitoring, this will take the form of an armoured fibre cable wrapped helically around each of the proposed 400 kV cables.

• Associated works in the foreshore include the reinforcement of the ground beneath and around the cables by various methods including Associated works in the foreshore include the reinforcement of the ground beneath and around the cables by various methods including concrete ramps, concrete cable channels, infalling with grove/concrete, articulated pipes gabion wall and rock protections where required.

• Connection of a 400 KV UGC lastallation and substation extension or the kripaddege 220/110 kV Electricity Substation.

• In the laying of the 4 no. 400 kV UGC (approx. 51 metres (ni) in length) from the southern foreshore of the Lower Shannon Estuarry, to a proposed extension (approx. 5,500 m2) to the north of the existing Klanddege 220/110 kV Electricity Substation.

• In particular the submarine cables to the existing (Alpaddege 220/110 kV Electricity Substation and exportance in the provision, within the proposed substation extension, of a 400/220 kV AlS compound, containing electrical equipment and epparatus to connect the submarine cables to the existing (Alpaddege 220/110 kV Electricity Substation including the following:

• In a not count treathers (approx. 7.5 m high);

• In a control treather the submarine cables to the existing (Alpaddege 220/110 kV Electricity Substation including the following:

• In a lighting particular and (approx. 9.5 m high);

• In a lighting particular and an accident access track (approx. 9 m high);

• In a lighting poles (approx. 9 m high);

• In a lighting poles (approx. 9 m high);

• In a lighting poles (approx. 9 m high);

• In a lighting the submarine cables of the existing electricity substations will

posed development includes works located within ESB Maneypoint Generation Station which is an Upper-fier establishment to which the Chem(Control of Major Accident Hazards Involving Dangerous Substances) Regulations 2015 (the COMAN Regulations) apply. Article 215 of the
1 and Development Regulations 2001 (as amended) applies to this development.
2 impact Statement has been prepared in respect of this application for Approval.
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not
3 including the Natura impact Statement, may be inspected free of charge or purchased on payment of this payment.

The Offices of An Bord Pleanála, 64 Martborough Street, Dublin 1, D01 V902

Clare County Council, Planning Department, Aras Contoe an Chlair, New Road, Ennis, Co. Clare V95 DXP2

Clare County Council, Planning Department, Rathoss, Irades, Co., Kerry V92 HYVI

The application may also be viewed on the application website: www.cirguidcrossshannon.ie.Submissions or observations may be made only to An Bord Pleanála ("The Board") 64 Marlborough Street, Dublin 1 during the above-mentioned period of seven weeks relating to —

the implications of the proposed development for proper planning and sustainable development; the likely adverse effects on the integrity of a European site, if carried out

the likely adverse effects on the integrity of a European site, if carried out

there is 3.00pm on 25th September 2020. Such submissions/observations must also include the following information:

The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to

which any correspondence relating to the application should be sent;

The reasons, considerations and arguments on which the submission or observation is based in full. (Article 217 of the Planning & Development

Regulations refers).

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

The Board may in respect of an application for permission/approval decide to —

a. Approve the proposed development;

b. Make such modifications to the proposed development as it specifies in its decision and Approve the proposed development as so modified; or Approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or

decisions may be subject to or without conditions, or

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleandla (Tel. 01-8588100). A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.L. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act, 2000, as amended. Practical information on the review mechanism can be accessed on the Board's website www.pleanala.te under the heading 'information on Cases / Weekly Lists'—see 'Judicial Review of Planning Decisions' notice, or on Citizens Information Service website www.citizensimformation.ie.

HEQUE IT OUT: Res-dents of Casements New, St Brendan's Ter-ace and Station Road,



COMHAIRLE CONTAE CHIARRAÍ COUNCI



PLANNING & DEVELOPMENT ACT 2000-2018 & PLANNING & DEVELOPMENT REGULATIONS 2001-2018

PUBLIC NOTICE
CONSTRUCT 1.3KM OF GREENWAY, TRALEE-FENIT GREENWAY
(BAWNBOY) AND ASSOCIATED SITE WORKS

Bawnboy, Tralee, Co. Kerry

Public Notice in Compliance with Part XI of the Planning & Development Act 2000-2018 as set down in Part 8 of the Planning and Development Regulations 2001-2018.

suant to the requirements of the above, Notice is hereby given that Kerry County Council poses to carry out the development, particulars of which are set out hereunder.

Location/Townland or Postal Address of the Proposed Development

Location: Bawnboy, Tralee, Co. Kerry
Townstand(s): Bawnboy, Ballynahoulort

lature and extent of the Proposed Works

The proposed development consists of the construction of 1.3km of greenway and associated site works. The greenway will form part of the Tralee-Fenit Creenway and will be for the sole use of pedestrians and cyclists. The works will consist of:

Iffing of the old railway rails, where present removal of the topsoil, where greenfield construction of a 3m wide paved surface (asphalt concrete) with a 1m wide grass verge on each side of the paved surface

retaining existing hedgerows, where present, to be left in-situ and repaired as required stock proofing fence, where required

stock proofing fence, where required

stock proofing fence, where required signage, road markings and traffic calming measures pedestrian / cycle and agricultural crossing points and gates, where required retaining and marking good the existing drainage

new drainage, as over the edge to drainage channels or filter drains, as necessary, and to existing drainage outlets

all other associated site works

Kerry County Council as the Competent Authority has concluded that the proposed project, individually, and in combination with other plans and projects, is not one which requires an Appropriate Assessment (AA) or an Environmental Impact Assessment (EIA) and is not likely have a significant effect on the environment.

suant to Article 120 (3)(b) a member of the public, may at any time before the expiration of 4 eks beginning on the date of the publication of this notice, seek an EIA screening determination m An Bord Pleanála as to whether the proposed development would have significant effects on

lans and Particulars of the proposed development are available for inspection or purchase, on bayment of a specified fee not exceeding the reasonable cost of making such a copy, during ourmal office hours from **Thursday 23rd July 2020 until 3rd September 2020** at the

- Kerry County Council, Tralee Municipal District Office, Princes Quay, Tralee, Co. Kerry County Council, Áras an Chontae, Rathass, Tralee, County Kerry. Kerry County Council Website www.kerry.coco.le

Submissions and Observations with respect to the proposed development dealing with proper planning and sustainable development in which the development would be situated, may be made in writing and clearly marked Tralee-Fent's Greenway (Bawnboy), Tralee, Co. Kerry: An Adviser is available to explain the plans and particulars by appointment only at 066 7191300.

Administrative Officer, Capital Infrastructure Unit Kerry County Council Tralee Municipal District Offices Princes Quay

Email to: CIU@Kerrycoco.ie

comply with its statutory/legal obligations. Such information will b Council's privacy statement which is available at <u>www.ketry.coco.ie</u> And must be received by: 5.00 p.m. on Friday 4th September 2020. Personal information is collected by Kerry County Council to enable the pusubmission/enquiry. Kerry County Council can legally process this information will be proced comply with its statutory/legal obligations. Such information will be proced. nable the processing of your his information as necessary to ill be processed in line with the

Siniú: Padraig Corkery Senior Executive Officer/Feidhmeannach Sinsearach Corporate Affairs/Gnóthaí Corparáideacha



AN CHUIRT DUICHE (THE DISTRICT COURT)
DISTRICT COURT AREA OF KILLORGLIN DISTRICT NO.17
INTOXICATING LIQUOR ACT, 1927 SECTION 12
NOTICE OF APPLICATION FOR A RESTAURANT CERTIFICATE
W.S. CATERING LIMITED APPLICANT:

TAKE NOTICE that W.S. CATERING LIMITED having its Registered Office at Killarglin, in the County of Kerry the holder of an on-Licence in respect of the premises known as "Bunkers" Killarglin in the Court Area and District aforesaid intends to apply to the DISTRICT COURT at Killarglin, sitting at Caherciveen, on the 10th day of September, 2020 at 10.30n.m., for a Certificate certifying that the said premises are a RESTAURANT for the purpose of the Intoxicating liquor Act, 1927.

Dated this 20th day of July 2020.

PADRAIG J. O'CONNELL, SOLICITOR FOR APPLICANT, GLEBE LANE, KILLARNEY, CO. KERRY

The Superintendent of An Garda Siochána, Killarney, Co. Kerry.
The Sergeant-in-Charge, of the Garda Siochana, Killorglin, Co. Kerry.
The Clerk of the District Court, Centrepoint, John Jee Sheethy Road, Tralee, Co. Kerry
Fire Officer, of Kerry County Council, Balloonagh, Tralee, Co. Kerry.
Secretary, of Kerry County Council, County Buildings, Tralee, Co. Kerry.

SHOLVOIT ON SHOW

Notice of Direct Planning Application to An Bord Pleanala for Approval in Respect of a Strategic Infrastructure Development
(a proposed Electricity Transmission Development)

Clare County Council and Kerry County Council
In accordance with Section 182A of the Planning and Development Act, 2000 (as amended), EirGrid Pic, with the consent and approval of the Electricity Supply Board (ESB), gives notice of its intention to seek the Approval of An Bord Pleanala in relation to a proposed electricity transmission infrastructure development and associated works (known as the 'Cross Shannon 400 kV Cable Project') generally comprising the laying of 400 kV underground cables (UGC) across the Lower Shannon Estuary, between the existing Moneypoint 400 kV Electricity Substation in the townland of Kripaddoge, Co. Kerry: The proposed development comprises 3 main elements.

roposed development complises 3 main elements:

Connection of a 400 kV UGC installation at the Moneypoint 400 kV Electricity Substation (Co. Clare), including:

o the laying of 3 no. 400 kV UGC installation at the Moneypoint 400 kV Electricity Substation (Co. Clare), including:

o the laying of 3 no. 400 kV UGC installation at the Moneypoint 400 kV Electricity Substation 400 kV Electricity Substation and 3 no. land-submarine transition joint bays located east of the existing Moneypoint deneration Station. The UGC will be installed by standard trenching and includes the provision of 3 no. Joint bays along their length and the associated provision, upgrading and/or extension of existing internal access tracks to provide operational vehicular access.

othe provision of 4 no. land-submarine transition joint bays located east of the existing Moneypoint Generation Station to contect the land cables to submarine cables (this arrangement also includes a land-submarine transition joint bay for the spare submarine cable).

Laying of 4 no. 400 kV Submarine Cables across the Lower Shannon Estuary, including:

othe laying of 4 no. 400 kV Submarine cables (approx. 2.8 km each) from the proposed land-submarine transition bays located east of the existing Moneypoint Generation Station in Co. Clare across the Lower Shannon Estuary to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Moneypoint Generation Station in Co. Clare across the Lower Shannon Estuary to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Moneypoint Generation belong the existing Moneypoint Generation in Co. Clare across the Lower Shannon Estuary to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Moneypoint Generation belong to the installation of Committee (AIS) Compound at the existing Moneypoint Generation belong to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Moneypoint Generation to the installation of Committee (AIS) Compound at the existing

Associated works in the forestore include the reinforcement of the ground beneath and around the cables by various methods including:

Connection of a 400 kV UGC laptrox. 51 metres (m) in length from the southern forestore of the proposed 400 kV Electricity Substation, within the proposed 220/110 kV Electricity Substation including the following:

a 9 no. surge arrestors (approx. 7.9 m high);

a 1 no. 400 / 220 kV transformer (approx. 9.8 m high);

a 1 no. suscended the reinforcement of the proposed. Significant in the submarine cables to the post insulators (approx. 9.8 m high);

a 1 no. suscended the reinforcement of the proposed and by the electricity substations.

Connection of a 400 kV UGC laptrox. 7.2 m high);

a 1 no. suscended the reinforcement of the ground beneath and around the cables by various methods including concrete ramps, concrete cable of the provision, within the proposed substation extension at the KIlpaddoge 220/110 kV Electricity Substation.

Contaction of the 4 no. 400 kV UGC laptrox. 5. metres (m) in length from the southern foreshore of the Lower Shamon Estuary to a proposed extension (approx. 5,500 mz) to the provision, within the proposed substation extension, of a 400/220 kV AlS compound, containing electrical equipment and apparatus to connect the submarine cables to the existing kilpaddoge 220/110 kV Electricity Substation including the following:

a 9 no. carba examples (approx. 9.8 m high);

a 1 no. subscended the examples (approx. 9.8 m high);

a 1 no. subscended the examples (approx. 9.8 m high);

7,6 m high);

no. instrument transformers (approx. 7.6 m high);
no. circuit breakers (approx. 7.5 m high);
no. lightning protection masts (approx. 25 m high);
no. lightning protection masts (approx. 25 m high);
n costociated access brack (approx. 155 m in length and 5 m in width);
n costociated access brack (approx. 155 m in length and 5 m in width);

2 no lighting poles (approx. 9 m high);
no. 220 kV UGC (approx. 151 m in length);
ne AlS compound will be enclosed by a palisade fence (approx. 2.6 m in height).
ne AlS compound will be enclosed by a palisade fence (approx. 2.6 m in height).
development includes all associated and anciliary development, including communication links, temporary construction compounds, temporary construction tracks, site landscaping works and vegetation removal. Access to the existing electricity substations will be retained from their existing entrances onto the N67 Road in Co. Clare of Tarbert Coast Road in Co. Kerry.

Anneypoint Generation Station is licensed by the Environmental Protection Agency (EPA) under an Industrial Emissions (IE) Licence (Ref. 19605-04).

roposed development-includes works located within ESB Moneypoint Generation Station which is an Upper-tier establishment to which the Chemicals Act (Control of Major ent Hazards Involving Dangerous Substances) Regulations 2015 (the COMAH Regulations) apply. Article 215 of the Planning and Development Regulations 2001 (as amend as to this development.

observations may be made only to An Bord Pleanala ("The Board")

Applies to this prepared in respect of this application for Approval.

I Natural Impact Statement has been prepared in respect of this proposed development.

I Poreshore Licence is separately required to be obtained in respect of this proposed development.

The application for Approval, including the Natura Impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not exceeding the reasonal finaking such copy) during public opening hours for a period of seven weeks commencing on 7th August 2020 at the following locations:

The Offices of An Bord Pleandia, 64-Martborough Street, Dublin 1, Dot 1992

Clare County Council, Planning Department, Arias Contae an Cháir/New Road Emits, Co. Clare V95 DXP2

Kerry County Council, Planning Department, Rathass, Tralee, Co. Kerry V92 H7V1

The application may also be viewed on the application website: www.eigridcrossshannon.ie.Submissions or observations may be made only to Am Bord Pleandia ("The Board He Implications of the proposed development; and the implications of the proposed development for proper planning and sustainable development;

the likely adverse effects on the integrity of a European site, if carried out the viewed of the proposed development; and in the likely adverse effects on the integrity of a European site, if carried out the viewed by the Board no later than 5.30pm on 25th September 2020. Such submissions/observations must also include the following information:

The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relations than 4th or the proposed development.

imber 2020. Such submissions/observations must also include the following information:

name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence application should be sent;

subject matter of the submission or observation; and

reasons, considerations and arguments on which the submission or observation is based in tuil. (Article 217 of the Planning & Development Regulations refers).

The submissions or observations which do not comply with the above requirements cannot be considered by the Board.

Out may at its absolute discretion hold an oral hearing on the application. (For further details see 'A Guide to Public Participation in Strategic Infrastructure Developing the property of the property of the planning that is absolute discretion hold an oral hearing on the application.

Board may in respect of an application for permission/approval decide to -sprove the proposed development;

posed development as it specifies in its decision and Approve the proposed development as so modified, or development (with or without specified modifications of it of the foregoing kind), and any of the above decis

cisions may be subject to or without

d. Refuse to grant the permission/approval.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanala (Tel. 01.8588100). A person may questithe validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act, 2000, as amended. Practical information on the review mechanism can be accessed on the Board's website www.pleanala.ie under the heading 'information on Cases / Weekly Lists' — see 'Judicial Review of Planning Decisions' notice, or on Citizens Information Service website

PORIC NOTICES

PUBLIC MOTICES



ROADS ACT 1993, AS AMENDED PART 19 & SECTION 199(1) SECTON 36

DRAFT CONTROL OF PARKING BYE LAWS

South Dublin County Council in exercise of its powers conferred on it by Section 199(1) of the Local Government Act 2001, and Section 36 of the Road Traffic Act 1994, as amended, hereby gives notice that it has published draft Control of Parking Bye Laws 2020 to control and regulate parking in its administrative area.

The draft Bye Laws are available for viewing on the Council's Public Consultation Portal at http://consult.sdublin.coco.ie from Thursday 23rd July 2020 until Friday 28th August 2020 inclusive.

Interested parties are encouraged to make observations and / or submissions on the draft ByeLaws via the portal.

The Council will consider submissions made by any persons in relation to the draft Bye-Laws. Alternatively, written submissions may be posted to the Senior Executive Officer, Land Use Planning and Transportation Department, South Dublin County Council, County Hall, Tallaght, Dublin 24.

Only postal submissions received by 4.00pm on Friday 11th September 2020 (addressed as set out above), or on-line via the portal by midnight on 11th September 2020 will be considered.

Submissions must be clearly marked: Draft Control of Parking Bye Laws 2020.

Submissions and observations should be made by **ONE** medium only and will only be accepted in either format as outlined above.

Web: www.sdcc.ie

MOTORS TOR SALM

We make motors move





MOTORS FOR HIRE

VAN RENTAL FROM HERTZ.
Daily / Weekly Rentals.
Insurance Included, 1890 826
826 / hertzvanrental.com

Waterford

4* Granville 40th Anniversary room only €40pps 051 305555

VIDEO REVIEWED

SOUVENIR POSTER

PREMIER LEAGUE CHAMPIONS POSTER PICK UP YOUR FREE DOUBLE-SIDED DOUBLE-SI _IVERPOO!

NSIDE THIS FRIDAY'S Trish Independent

PLANNINGS

Clare County Council Glasha More,

Doolin, Co Clare Take notice that Noel McDonagh Gearoid Kirwan intend to apply to Take notice that Martin Murphy intends to apply for permission to the above Planning Authority for build a new dwelling, install a permission to construct a private wastewater treatment system and garage / domestic store at above the existing dwelling and all may be inspected or purchased at a associated site and ancillary works fee not exceeding the reasonable at the above address. The planning cost of making a copy, at the application may be inspected or offices of the Planning Authority purchased at a fee not exceeding during its public opening hours. A the reasonable cost of making a submission or observation in copy, at the offices of the Planning relation to the application may be Authority, during its public open- made to the Authority in writing on ing hours. A submission or payment of the prescribed fee observation in relation to the within the period of 5 weeks application may be made in writing beginning on the date of receipt by to the Authority on payment of the the Authority of the application. prescribed fee of €20, within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

Clare County Council Knockalisheen Meelick, Co Clare

Thomas Cronin is applying to the at 8 Four Seasons Drive, Ennis. tants (086 602 0453), on behalf of above Authority for retention The planning application may be Marianne Murphy intends to apply permission for the following: a) as inspected or purchased at a fee not to the Planning Authority for constructed dwelling house. b) as exceeding the reasonable cost of planning permission to construct a constructed detached garage c) as making a copy, at the offices of the single dwelling house, garage, constructed entrance wall d) as Planning Authority during its advanced wastewater treatment constructed garden wall and all associated site works at Knockalis- sion or observation in relation to at the above address. The planning heen Meelick, Co Clare. That the the application may be made in application may be inspected or planning application may be writing to the Planning Authority purchased at a fee not exceeding inspected or purchased at a fee not on payment of the prescribed fee, the reasonable cost of making a exceeding the reasonable cost of €20, within the period of 5 weeks copy, at the offices of the Planning making a copy, at the offices of the beginning on the date of receipt by Authority during its public opening Planning Authority during its the Authority of the application hours and that a submission or public opening hours and that a and such submissions or observa- observation in relation to the submission or observation in tions will be considered by the application may be made to the relation to the application may be Planning Authority in making a Authority in writing on payment of made to the Authority in writing on decision on the application. The the prescribed fee within the period payment of the prescribed fee Planning Authority may grant of $\hat{5}$ weeks beginning on the date within the period of 5 weeks permission subject to or without of receipt by the Authority of the beginning on the date of receipt by conditions or may refuse to grant application. Opening hours 9am to the Authority of the application

Clare County Council Daughnieve, Coolmeen,

Kildysart, Co Clare Take notice that Keith Farrell intends to apply to the Planning Authority for permission to construct a new dwelling house and garage complete with a new entrance, sewage treatment system and ancillary works at the above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority, Clare County Council, Áras Contae an Chláir, New Road, Ennis during its public opening hours and that a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Planning Authority of the application

Clare County Council Cragbrien, Ballynacally, Ennis, Co Clare

Take notice that John Mangan intends to apply to the Planning Authority for permission to construct a new dwelling house and garage complete with a new entrance, sewage treatment system and ancillary works at the above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority, Clare County Council, Áras Contae an Chláir, New Road, Ennis during its public opening hours and that a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Planning Authority of the application.

Clare County Council Toonagh, Fountain, Co Clare

Take notice that I, Nora Custy intend to apply to Clare County Council for permission to increase the number of children from 10 to 20 at existing crèche on foot of original planning granted under ref no. P.09-791at above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy at the offices of the Planning Authority of Clare County Council, Planning Department, Áras Contae an Chláir, New Road, Ennis, Co Clare during its public opening hours. A submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee of €20 within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

Clare County Council 141 Cahercalla Estate,

Ennis, Co Clare We, Donal and Theresa Pyne intend to apply for permission for the construction of first floor extension consisting of bedroom with en-suite and to make alterations and renovations to the existing dwelling at the above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority during its public opening hours and that a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Authority of the application. The Planning Authority may grant permission subject to or without conditions, or may refuse to grant permission

Clare County Council Nooan, Ruan, Co Clare

Take notice that Karen and

Clare County Council 8 Four Seasons Drive, Ennis, Co Clare

Mark and Colette Waters wish to public opening hours. A submis- system and ancillary site works all permission.

Clare County Council Carrownahooan West, Kilshanny, Co Clare

intends to apply for permission to build a garage and storage shed and all associated site and ancillary planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority, during its public opening hours. A submission or observation in relation to the application may be made in writing to the Authority on payment of the prescribed fee of €20, within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

Clare County Council Ballyvorgal South,

Sixmilebridge, Co Clare apply for permission to construct Take notice that Enda Colleran an extension to existing dwelling MSc (Env. Eng.), BSc, MIEI of house and all associated site works Environmental Planning Consul-4pm.

Clare County Council Quilty West, Quilty, Co Clare

Take notice that Mike Scanlon and to retain existing extensions and permission to demolish an existing all associated site works, extend address. The planning application works at the above address. The covered awning area to their shed to the rear of existing address. The planning application construct a new extension to the may be inspected or purchased at a rear of this dwelling along with fee not exceeding the reasonable ancillary works at the above of the Planning Authority, during may be inspected or purchased at a its public opening hours. submission or observation in cost of making a copy, at the relation to the application may be offices of the Planning Authority, made in writing to the Authority on Clare County Council, Áras Contae payment of the prescribed fee an Chlair, New Road, Ennis during beginning on the date of receipt by the Authority of the application.

Clare County Council Ballyveskil, Tiermaclane,

Co Clare Take Notice that I Kellie Whelan intend to apply to Clare County application. Council for permission for the construction of a dwelling house, garage and proprietary waste treatment plant and to utilise existing entrance and roadway to access site including upgrades to same and all ancillary site works. The Planning Application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy at the offices of the Planning Authority of Clare County Council, Planning Department, Áras Contae an Chláir, New Road, Ennis, Co Clare during it's public opening hours. A submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee of €20 within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

PLANNING AND DEVELOPMENT ACT 2000 (AS AMENDED) Notice of Direct Planning Application to An Bord Pleanála for Approval in Respect of a Strategic Infrastructure Development

(a proposed Electricity Transmission Development) Clare County Council and Kerry County Council

In accordance with Section 182A of the Planning and Development Act, 2000 (as amended), EirGrid Plc, with the consent and approval of the Electricity Supply Board (ESB), gives notice of its intention to seek the Approval of An Bord Pleanála in relation to a proposed electricity transmission infrastructure development and associated works (known as the 'Cross Shannon 400 kV Cable Project') generally comprising the laying of 400 kV underground cables (UGC) across the Lower Shannon Estuary, between the existing Moneypoint 400 kV Electricity Substation in the townland of Carrowdotia South Co. Clare and the existing Kilpaddoge 220/110 kV Electricity Substation in the townland of Kilpaddoge, Co. Kerry: The proposed development comprises 3 main elements:

1. Connection of a 400 kV UGC Installation at the Moneypoint 400 kV Electricity Substation (Co. Clare), including:

o the laying of 3 no. 400 kV UGC [approx. 1.8 kilometres (km) each] between the existing Moneypoint 400 kV Electricity Substation and 3 no. land-submarine transition joint bays located east of the existing Moneypoint Generation Station. The UGC will be installed by standard trenching and includes the provision of 3 no. joint bays along their length and the associated provision, upgrading and/or extension of existing internal access tracks to provide operational vehicular access.

o the provision of 4 no. land-submarine transition joint bays located east of the existing Moneypoint Generation Station to connect the land cables to submarine cables (this arrangement also includes a land-submarine transition joint bay for the spare submarine cable).

2. Laying of 400 kV Submarine Cables across the Lower Shannon Estuary, including:

o the laying of 4 no. 400 kV submarine cables (approx. 2.8 km each) from the proposed land-submarine transition bays located east of the existing Moneypoint Generation Station in Co. Clare across the Lower Shannon Estuary to the proposed 400 kV Air Insulated Switchgear (AIS) Compound at the existing Kilpaddoge 220/110 kV Electricity Substation in Co. Kerry. The submarine cables will be installed by standard submarine installation techniques, which primarily involves them being buried in the seabed o the installation of communication links between both substations, this will take the form of a fibre optic

cable that will be integrated into each of the proposed 400 kV cables. o The installation of fibre optic cables for maintenance and cable monitoring, this will take the form of an

armoured fibre cable wrapped helically around each of the proposed 400 kV cables. o Associated works in the foreshore include the reinforcement of the ground beneath and around the cables by various methods including concrete ramps, concrete cable channels, infilling with gravel/

concrete, articulated pipes, gabion wall and rock protections where required. 3. Connection of a 400 kV UGC Installation and substation extension at the Kilpaddoge 220/110 kV $\,$

Electricity Substation (Co. Kerry) including: o the laying of the 4 no. 400 kV UGC [approx. 51 metres (m) in length] from the southern foreshore of the Lower Shannon Estuary, to a proposed extension (approx. 5,500 m2) to the north of the existing

Kilpaddoge 220/110 kV Electricity Substation. o the provision, within the proposed substation extension, of a 400/220 kV AIS compound, containing electrical equipment and apparatus to connect the submarine cables to the existing Kilpaddoge 220/110

kV Electricity Substation including the following:

- 9 no. surge arrestors (approx. 7.9 m high); ■ 6 no. cable sealing ends (approx. 7.4 m high);
- 1 no. 400 / 220 kV transformer (approx. 8.9 m high); ■ 9 no. post insulators (approx. 9.8 m high);
- 1 no. disconnector (approx. 8.6 m high);
- 9 no. instrument transformers (approx. 7.6 m high); ■ 3 no. circuit breakers (approx. 7.5 m high);
- 5 no. lightning protection masts (approx. 25 m high); ■ a control building (approx. 14.6m x 6.6m x 4.6m high);
- an associated access track (approx. 155 m in length and 5 m in width);
- 12 no lighting poles (approx. 9 m high);
- 3 no. 220 kV UGC (approx. 151 m in length); ■ The AIS compound will be enclosed by a palisade fence (approx. 2.6 m in height).

The proposed development includes all associated and ancillary development, including communication links, temporary construction compounds, temporary construction tracks, site development, landscaping works and vegetation removal. Access to the existing electricity substations will be retained from their existing entrances onto the N67 Road in Co. Clare and the L1010 Tarbert Coast Road in Co. Kerry. ESB Moneypoint Generation Station is licensed by the Environmental Protection Agency (EPA) under an Industrial Emissions (IE) Licence (Ref: P0605-04).

The proposed development includes works located within ESB Moneypoint Generation Station which is an Upper-tier establishment to which the Chemicals Act (Control of Major Accident Hazards Involving Dangerous Substances) Regulations 2015 (the COMAH Regulations) apply. Article 215 of the Planning and Development Regulations 2001 (as amended) applies to this development.

A Natura Impact Statement has been prepared in respect of this application for Approval. A Foreshore Licence is separately required to be obtained in respect of this proposed development.

The application for Approval, including the Natura Impact Statement, may be inspected free of charge or purchased on payment of a specified fee (not exceeding the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 7th August 2020 at the following lo-

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1, D01 V902 • Clare County Council, Planning Department, Áras Contae an Chláir, New Road, Ennis, Co. Clare V95
- Kerry County Council, Planning Department, Rathass, Tralee, Co. Kerry V92 H7VT

The application may also be viewed on the application website: www.eirgridcrossshannon.ie. Submissions or observations may be made only to An Bord Pleanála ("The Board") 64 Marlborough Street, Dublin 1 during the above-mentioned period of seven weeks relating to -

the implications of the proposed development for proper planning and sustainable development;

ii. the likely effects on the environment of the proposed development; and iii. the likely adverse effects on the integrity of a European site, if carried out

Any submission/observation must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board no later than 5.30pm on 25th September 2020. Such submissions/ observations must also include the following information:

• The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent; • The subject matter of the submission or observation; and

• The reasons, considerations and arguments on which the submission or observation is based in full. (Article 217 of the Planning & Development Regulations refers). Any submissions or observations which do not comply with the above requirements cannot be considered

by the Board. The Board may at its absolute discretion hold an oral hearing on the application. (For further details see

'A Guide to Public Participation in Strategic Infrastructure Development' on the Board's website www. pleanala.ie).

The Board may in respect of an application for permission/approval decide to a. Approve the proposed development;

b. Make such modifications to the proposed development as it specifies in its decision and Approve the proposed development as so modified; or

c. Approve, in part only, the proposed development (with or without specified modifications of it of the foregoing kind), and any of the above decisions may be subject to or without conditions, or d. Refuse to grant the permission/approval.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01-8588100). A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S.I. No. 15 of 1986, as amended), in accordance with Section 50 of the Planning and Development Act, 2000, as amended. Practical information on the review mechanism can be accessed on the Board's website www.pleanala.ie under the heading 'Information on Cases / Weekly Lists' - see 'Judicial Review of Planning Decisions' notice, or on Citizens Information Service website www.citizensinformation.ie.

Clare County Council Ballyvonnavaun, Clarecastle, Ennis, Co Clare

Take notice that Declan Bell and Tina Byrt intend to apply to the Niamh McCannon intend to apply Planning Authority for permission to the Planning Authority for (a) dwelling house at the above dwelling house (b) permission to cost of making a copy at the offices address. The planning application fee not exceeding the reasonable within the period of 5 weeks its public opening hours and that a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee associated site development works within the period of 5 weeks beginning on the date of receipt by the Planning Authority of the

Clare County Council Tullagower, Cooraclare,

Co Clare Chit Irish Forestry Ltd intends to apply for Planning Permission for to construct an entrance and access road to existing forestry lands and associated site works. The application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy at the offices of the Planning Authority, Clare County Council, New Road, Ennis, Co Clare during its public opening hours. A submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee of €20 within the period of five weeks beginning on the day of receipt by the authority of the application. Such submissions or observations will be considered by the Planning Authority in making a decision on the application and the Planning Authority may grant permission with or without conditions or may refuse to grant

Clare County Council Derrynalecka, Kilmurry McMahon, Kilrush, Co Clare

We, Newfield Agricultural Advice and Services 087-6897335 wish to apply to Clare County Council on behalf of Ger Morrissey, for planning permission to construct a slatted beef house with an underground slurry tank with internal and external feeding passages on his farm at Derrynalecka, Kilmurry McMahon, Kilrush, Co Clare. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy at the offices of the Planning Authority of Clare County Council, Planning Department, Áras Contae the authority of the application.

Clare County Council Bella, Kilkee, Co Clare

Take notice that Martin McQuaid intends to apply to the Planning Authority for 1/ Retention permission to retain existing under slat tank and 2/ For permission to construct shed to cover existing under slat tank plus all ancillary site works at the above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority, Clare County Council, Áras Contae an Chláir, New Road, Ennis, Co Clare during its public opening hours and that a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Authority of the application. The Planning Authority may grant permission subject to or without conditions, or may refuse to grant **sales@clarechampion.ie**

Clare County Council Manusmore, Clarecastle,

Co Clare Renewable Energy Systems (RES) Ltd, intend to apply for permission for development at this site at Manusmore, Clarecastle, Co Clare. The development will consist of a planning permission for a period of 5 years to construct and complete a Solar PV Energy development with a total site area of 99.2 hectares, to include a single storey electrical substation building, electrical transformer and invertor station modules, solar PV panels ground mounted on support structures, internal access tracks, security fencing, electrical cabling and ducting, CCTV and other ancillary infrastructure, drainage, additional landscaping and habitat enhancement as required and including works relating to the access to the site. The solar farm will be operational for 35 years. That the planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority during its public opening hours and that a submission or observation in relation to the application may be made to the authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

Clare County Council Ballyhee, Larchill,

Ennis, Co Clare Take notice that Mark Hanrahan intends to apply for permission to construct a dwelling house and garage, with effluent treatment system, new entrance from public road, and all associated site works, at above address. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Panning Authority during its public opening hours. A submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Authority of the application and such submissions or observations will be considered by the Planning Authority in making a decision on the application. The Planning Authority may grant permission subject to or without conditions or may refuse to grant

Clare County Council Bealkelly, Ogonnelloe, Co Clare

permission.

Planning permission is sought by Kevin and Karen Woulfe to construct a detached domestic garage and to relocate the previously approved proposed site entrance, to the front of their an Chlair, New Road, Ennis, Co re-designed house (Planning Regis-Clare during it's public opening ter P20/322 - change of house hours. A submission or observation design under previously granted; in relation to the application may Planning Permission P12-121 and be made to the Authority in writing Extension of Duration Planning on payment of the prescribed fee of Permission P17-234 (to demolish €20 within the period of 5 weeks existing sub-standard house and beginning on the date of receipt by erect a replacement dwelling house and install an effluent system and percolation area and all associated site works), at Bealkelly, Ogonnelloe, Co Clare. The planning application may be inspected or purchased at a fee not exceeding the reasonable cost of making a copy, at the offices of the Planning Authority during its public opening hours and a submission or observation in relation to the application may be made to the Authority in writing on payment of the prescribed fee within the period of 5 weeks beginning on the date of receipt by the Authority of the application.

FOR ALL YOUR PLANNING NEEDS Contact us at 065 6828105 or email



COMHAIRLE CONTAE AN CHLÁIR CLARE COUNTY COUNCIL

NOTICE PURSUANT TO SECTION 15 OF THE HOUSING (MISCELLANEOUS PROVISIONS) ACT 2014

Tenancy at 19 Wood Road, Kilrush, Co. Clare. V15FV32.

Clare County Council, the Housing Authority for the County of Clare, has reason to believe that 19 Wood Road, Kilrush, Co. Clare. V15FV32 ("the dwelling") is currently unoccupied and has served a Notice on the property pursuant to Section 15 of the Housing (Miscellaneous Provisions) Act 2014.

TAKE NOTICE that the tenants are required to inform the Council in writing by 21st August, 2020 if they intend to occupy the dwelling as their normal place of residence.

If this requirement is not complied with and it appears to the Council that the dwelling remains unoccupied, a further Notice will be served bringing the tenancy agreement to an end with immediate effect.



COMHAIRLE CONTAE AN CHLÁIR CLARE COUNTY COUNCIL

NOTICE OF CONSIDERATION OF **SETTING A LOCAL ADJUSTMENT FACTOR**

The Finance (Local Property Tax) Act 2012 (as amended). makes specific provision that elected members of a local authority may pass a formal resolution to vary the basic rate of the Local Property Tax for their administrative area by a percentage known as the local adjustment factor. At the meeting set by Clare County Council to consider this matter, the members may set a local adjustment factor within the range of +/- 15% of the basic rate, or, may decide not to adjust the basic rate.

Clare County Council will meet in September 2020 to consider the setting of a local adjustment factor.

Clare County Council welcomes written submissions from the public on this matter specifically covering the potential effects of varying the basic rate of the Local Property Tax on businesses, individuals and on local authority services.

Submissions must be received by 24th August 2020 and be sent to:

SEO Corporate Services Clare County Council New Road Ennis Co. Clare

Email to: lptsubmissions@clarecoco.ie

Make an online submission to: <u>lpt.clarecoco.ie</u>

Pat Dowling

Chief Executive Dated: 23th July 2020

PLEASE NOTE that this is a public consultation process and submissions may be published on the Clare County Council



COMHAIRLE CONTAE AN CHLÁIR CLARE COUNTY COUNCIL

NOTICE PURSUANT TO SECTION 15 OF THE HOUSING (MISCELLANEOUS PROVISIONS) ACT 2014

Tenancy of Apt. 1 St. Helen's Park, Ballymurtagh, Shannon, Co. Clare. Clare County Council, the Housing Authority for the County of Clare, has reason to believe that Apt. 1 St. Helen's Park,

currently unoccupied and has served a notice on the property

pursuant to Section 15 of the Housing (Miscellaneous Provisions) Act 2014. TAKE NOTICE that the Tenants are required to inform the Council in writing by 17th August 2020 if they intend to

Ballymurtagh, Shannon, Co. Clare ("the dwelling") is

occupy the dwelling as their normal place of residence. If this requirement is not complied with and it appears to the Council, that the dwelling remains unoccupied, a further notice will be served bringing the Tenancy Agreement to an end with immediate effect.

NOTICE PURSUANT TO SECTION 15 OF THE HOUSING (MISCELLANEOUS PROVISIONS) ACT 2014

Tenancy of Apt. 2 St. Helen's Park, Ballymurtagh, Shannon, Co. Clare.

Clare County Council, the Housing Authority for the County of Clare, has reason to believe that Apt. 2 St. Helen's Park, Ballymurtagh, Shannon, Co. Clare ("the dwelling") is currently unoccupied and has served a notice on the property pursuant to Section 15 of the Housing (Miscellaneous Provisions) Act 2014.

TAKE NOTICE that the Tenants are required to inform the Council in writing by 17th August 2020 if they intend to occupy the dwelling as their normal place of residence.

If this requirement is not complied with and it appears to the Council, that the dwelling remains unoccupied, a further notice will be served bringing the Tenancy Agreement to an end with immediate effect.

NOTICE PURSUANT TO SECTION 15 OF THE HOUSING (MISCELLANEOUS PROVISIONS) ACT 2014 Tenancy of Bay 4, Ballymurtagh,

Shannon, Co. Clare. Clare County Council, the Housing Authority for the County

of Clare, has reason to believe that Bay 4, Ballymurtagh,

and has served a notice on the property pursuant to Section 15 of the Housing (Miscellaneous Provisions) Act 2014. TAKE NOTICE that the Tenants are required to inform the Council in writing by 17th August 2020 if they intend to

Shannon, Co. Clare ("the dwelling") is currently unoccupied

occupy the dwelling as their normal place of residence. If this requirement is not complied with and it appears to the Council, that the dwelling remains unoccupied, a further

notice will be served bringing the Tenancy Agreement to an

NOTICE PURSUANT TO SECTION 15 OF THE HOUSING (MISCELLANEOUS PROVISIONS) ACT 2014

Tenancy of 29 Oakwood Drive, Watery Rd, Ennis, Co. Clare.

end with immediate effect.

Clare County Council, the Housing Authority for the County of Clare, has reason to believe that No. 29 Oakwood Drive, Watery Rd, Ennis, Co. Clare ("the dwelling") is currently unoccupied and has served a Notice on the property pursuant to Section 15 of the Housing (Miscellaneous Provisions) Act

TAKE NOTICE that the tenant(s) are required to inform the Council in writing by 21st August, 2020 if they intend to occupy the dwelling as their normal place of residence.

If this requirement is not complied with and it appears to the Council that the dwelling remains unoccupied, a further Notice will be served bringing the tenancy agreement to an end with immediate effect.

